



# WATER CAPACITY ANALYSIS

---

Orange Corp Yard Workforce Housing

637 West Struck Avenue

Orange, CA 92867

June 1, 2020

Prepared by:



John Deykes

26131 Via Oceano

Mission Viejo, CA 92691

949-322-3657

# TABLE OF CONTENTS

---

Introduction .....	2
Project and Site Description .....	3
Existing Water Capacity .....	4
Proposed Water Demands.....	6
Conclusion.....	6
Appendix .....	7

## INTRODUCTION

---


This Water Capacity Analysis for the “Orange Corp Yard Workforce Housing” project was commissioned by C & C Development Co., LLC and prepared by So Cal Civil Solutions, Inc. The purpose of this study is to evaluate the capacity of the existing water system and the capacity of the system to serve the proposed project.

## PROJECT AND SITE DESCRIPTION

---

The proposed project site encompasses 2.8 acres at 637 West Struck Avenue in the City of Orange, California (see Site Map). The proposed housing project will consist of 62 workforce units in a new multi-family complex. This project will be subdivided from the existing eastern half of the city of Orange Corporate Yard by processing and recording a new parcel map, 2020-127.


### Site Map



## EXISTING WATER CAPACITY

---

The City of Orange owns, operates, and maintains the water system in the vicinity of this site, which consists of a 10" CIP mainline that runs easterly in West Struck Avenue to the cul de sac, then the main turns into an 8" DIP with runs northerly for approximately 300 ft. At that point the main turns west towards North Batavia Street. See City Water Atlas below.



A flow test was performed by SoCal Flow Testing on 3/18/20 on the nearest fire hydrant (2nd hydrant east of N Parker St on south side of W Struck Ave). The static pressure in the 10" main in Struck Avenue was 82 PSI, the 2-1/2 inch nozzle flow rate was 1,256 GPM with a residual pressure of 55 PSI. The calculated flow at 20 PSI residual is 4,432 GPM.

## HYDRANT FLOW TEST CALCULATOR: CALCULATE RATED CAPACITY AT 20 PSI

The Hydrant Flow Test Calculator measures the rated capacity at 20 psi of a fire hydrant. The rated capacity calculation is useful in determining the total water supply at a given point in the hydrant or water main. The calculation offers more useful information than the test flow by itself and is used by insurance underwriters. For more information see NFPA 291, AWWA M-17, or our web page on Hydrant Flow Testing.

Static Pressure (PSI):

82

Residual Pressure (PSI):

76

Total Test Flow-rate (GPM):

1256


**CALCULATE**

GPM at 20 psi: 4432

Class: AA

Marking color: Light Blue

9% Pressure Drop: 7.39%



## PROPOSED WATER CAPACITY

---

As mentioned before the proposed project proposes 62 workforce units. Per the current plumbing code, this project consists of two and three bedroom apartments with full bath, kitchen sink, and dishwasher having a total fixture count of 934 Fixture Units for the proposed project which equates to a peak water supply demand of 220 gallons per minute.

Land Use Type	Units	Fixture Units/ Unit (FU/DU)	Total Fixture Units	Water Supply Demand (gpm)
Workforce Units	62	15.1	934	220
		Total	934	220

The required fire flow for residential construction is 1,500 GPM. The proposed project water demand is 220 GPM. Fire plus domestic is 1,720 GPM. The calculated flow available in the 10 inch main is 4,432 GPM.

## CONCLUSION


---

Based on this water analysis, adequate capacity exists in the existing 10 inch main on W Struck Avenue. The proposed project water demands will have minimal impact on the existing system.

# APPENDIX

---

## Water Supply Systems Fixture Units and Demand





Orange City Fire Department  
Fire Prevention Division  
Flow Test Record



TEST HYDRANT DATA

LOCATION: 574 W Struck Ave.  
HYDRANT I.D. NO.: 2337 SIZE MAIN: 10" TYPE HYDRANT: wet  
STATIC (PSI): 82  
RESIDUAL (PSI): 76  
PRESSURE DROP (PSI): 6 "K" FACTOR FOR (PD1)\*: \_\_\_\_\_

FLOW HYDRANT(S) DATA

LOCATION NO. 1: 574 W. Struck I.D. NO.: 2336  
LOCATION NO. 2: \_\_\_\_\_ I.D. NO.: \_\_\_\_\_  
LOCATION NO. 3: \_\_\_\_\_ I.D. NO.: \_\_\_\_\_  
(MAIN)  
#1 PITOT-PSI 56 GPM 1256 (4" OR 2 1/2") 2 1/2"  
#2 PITOT-PSI \_\_\_\_\_ GPM \_\_\_\_\_ (4" OR 2 1/2") \_\_\_\_\_  
#3 PITOT-PSI \_\_\_\_\_ GPM \_\_\_\_\_ (4" OR 2 1/2") \_\_\_\_\_

CALCULATED TEST AND FLOW DATA  $Q1 \times PD2 K = Q2$   
(Completed by test company) PD1 K

STATIC (PSI) \_\_\_\_\_  
DESIRED RESID. \_\_\_\_\_  
PRESSURE DROP (PD2) \_\_\_\_\_ "K" FACTOR FOR (PD2) \_\_\_\_\_  
(ENTER K-FACTOR IN FORMULA)  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
(Q1) TIMES (PD2)K DIVIDED BY (PD1)K EQUALS (Q2) GPM @ 20 PSI RESIDUAL

TEST CONDUCTED FOR: 577 W. Struck Ave / Design  
(LOCATION & REASON)

NAME: Dan Hildebrandt  
TITLE: owner  
COMPANY: Socal Flow Testing  
DATE: 3/18/20 TIME: 10:45AM INSPECTOR: R. Desimone

**SoCal Flow Testing**  
**3741 Rose Dr, Yorba Linda, CA 92886**  
**714-261-5716 \*\*\* 714-393-3877**  
**email: info@socalflowtest.com**

**Hydrant Flow Test Report**

Project Orange Corporate Yard project Test date 3/18/20  
 Address 517 W Struck Ave Test time 10:45  
 City Orange State CA File no. \_\_\_\_\_

Test hydrant location 2<sup>nd</sup> hydrant east of N Parker St on south side of W Struck Ave  
 Hydr # H-J06-2337 Elev (ft +/-) Grade  
 Flow hydrant location 1<sup>st</sup> hydrant east of N Parker St on south side of W Struck Ave  
 Hydr # H-J06-2336 Elev (ft +/-) Grade

Static Pressure 82 PSI Report Date 3/18/20

Outlet	C-value	Diam	Pitot	Volume
A	<u>0.9</u>	<u>2.0</u>	<u>0</u> PSI	<u>0</u> GPM
B	<u>0.9</u>	<u>2.5</u>	<u>56</u> PSI	<u>1256</u> GPM
C	<u>0.9</u>	<u>3.0</u>	<u>0</u> PSI	<u>0</u> GPM
D	<u>0.83</u>	<u>4.0</u>	<u>0</u> PSI	<u>0</u> GPM


Residual Pressure 76 PSI at an observed volume of 1256 GPM

Projected Pressure 20 PSI calculates to a volume of 4432 GPM

Although the results are accurate for the date and time given, they may not accurately reflect higher or lower readings which vary due to seasonal conditions and time of day.

Per NFPA 24-10, Table C.4.10.1(a), note 1,  $Q = 29.84 \times c(d)^2(p)^{0.5}$   
 Per NFPA 24-10, Paragraph C.4.10.1.2,  $Q_r = Q_r \times (h/h_r)^{0.54}$

Test by: Dan Hildebrandt



Witness Robert DeSimone  
Fire Safety Specialist  
City of Orange Fire Dept

Client John Deykes  
SoCal Civil Solutions, Inc.  
(949) 322-3657

cc: rdesimone@cityoforange.org  
 john@socalcivilsolutions.com

